



# sprue

## **EU Declaration of Conformity** **(No. SAECD0C02-ST-620-06)**

In accordance with of European Parliament and Council Decision No 768/2008/EC Annex III

**Product model / product:**

Product Smoke Alarm Device  
Model/type FireAngel ST-620-XX, Angeleye ST-AE620-XX, Siemens Delta Reflex 5TC1292-2.  
XX- suffix denotes country code

**Manufacturer:**

Name Sprue Aegis Plc  
Address Vanguard Centre, Sir William Lyons Road, Coventry, CV4 7EZ, UK

*This declaration is issued under the sole responsibility of the manufacturer.*

**Object of the declaration:**

Product Thermally enhanced optical smoke alarm with 10-year battery  
Specification 3 V DC supply, 85dB(A) alarm, wall/ceiling mount, weight 157g

*The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:*

2014/30/EU The Electromagnetic Compatibility Directive  
2012/19/EU The Waste Electrical and Electronic Equipment Directive (WEEE)  
2011/65/EU The Restriction of Hazardous Substances Directive

*References to the relevant harmonised standards used or references to the other technical specifications in relation to which conformity is declared:*

Reference & Date	Title
EN 14604:2005+AC:2008	Smoke alarm devices
EN 50130-4:2011+A1:2014	Alarm systems - Part 4: Electromagnetic compatibility - Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems
EN 61000-6-3:2007	Electromagnetic compatibility. Generic standards. Emission standard for residential, commercial and light industrial environments

Please refer to document SADOP-ST-620-03 and 70762A-O2WA-DoP ( Siemens Delta Reflex 5TC1292-2. ) for the Declaration of Performance for the Construction Products Regulation

**Additional Information:**

Signed for and on behalf of: Sprue Aegis PLC  
Date/Place of issue: June 2017, Coventry, UK

X

I M Ballinger  
Certification Manager

EU Declaration of Conformity

