



sprue

EU Declaration of Conformity **(No. SAECD0C34-ST-625-04)**

In accordance with of European Parliament and Council Decision No 768/2008/EC Annex III

Product model / product:

Product Smoke Alarm Device
Model/type FireAngel ST-625-XX, Angeleye ST-AE625-XX,
XX- suffix denotes country code

Manufacturer:

Name Sprue Aegis Plc
Address Vanguard Centre, Sir William Lyons Road, Coventry, CV4 7EZ, UK

This declaration is issued under the sole responsibility of the manufacturer.

Object of the declaration:

Product Thermally enhanced optical smoke alarm with 10-year battery
Specification 3 V DC supply (2 x 1.5V AA), 85dB(A) alarm, wall/ceiling mount, weight 173g

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:

2014/30/EU	The Electromagnetic Compatibility Directive
2012/19/EU	The Waste Electrical and Electronic Equipment Directive (WEEE)
2011/65/EU	The Restriction of Hazardous Substances Directive

References to the relevant harmonised standards used or references to the other technical specifications in relation to which conformity is declared:


Reference & Date	Title
EN 14604:2005+AC:2008	Smoke alarm devices
EN 50130-4:2011+A1:2014	Alarm systems - Part 4: Electromagnetic compatibility - Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems
EN 61000-6-3:2007	Electromagnetic compatibility. Generic standards. Emission standard for residential, commercial and light industrial environments

Please refer to document SADOP-ST-625-02 for the Declaration of Performance for the Construction Products Regulation

Additional Information:

Signed for and on behalf of: Sprue Safety Products Ltd
Date/Place of issue: June 2017, Coventry, UK

X


I M Ballinger
Certification Manager

EU Declaration of Conformity

